

Residence Heating Systems

Lennox-Addington

Lennox-Addington has a hot water heating system and the student rooms are heated by the "convection" method. The temperature of the water is controlled centrally according to the outside air temperature. The students have no means of adjusting the temperatures in their rooms. The following rooms have thermostats and are exceptions to the above: 173, 175, 179, 181 for itself and 180, 182a for itself and 182, 273, and 275.

It is important that the area around the convector be kept clear at all times. The system relies on natural convection and anything in the path of the air entering or leaving the convector can seriously reduce the heating capacity.

Leaving windows open will cause pipes to freeze. Please ensure all windows are closed.

Lennox-Addington



Do not block the heater in your room with furniture, clothing, bedding, or any other belongings. The heater is located along the wall in your room, typically below a window – see Lennox Double (pictured above). Leave minimum 6 inches clearance between the heater and your belongings/furniture.